

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Magnetic contactor, Thermal overload relay, auxiliaries
Name and address of the applicant	LSIS Co., Ltd. 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do Korea, Republic of
Name and address of the manufacturer	LSIS Co., Ltd. 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do Korea, Republic of
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 LSIS Co., Ltd. Cheongju Plant 95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do Korea, Republic of
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Magnetic contactor: Ue up to 1000 Vac; Ith 25 A up to 1050 A, Ie (AC-3) up to 800 A (440 Vac) (AC-4) up to 630 A (440 Vac) 3 pole or 4 pole; Ui up to 1000 V; Uimp up to 8 kV; 50/60 Hz Thermal Overload relay: Ue up to 690 Vac; Ie up to 800 A 3 pole; Ui 690 V; Uimp 6 kV Interlock unit: UR-02 Auxiliary contact AC-15; DC-13 120 V up to 600 V; up to 6 A See annex for further ratings
Trademark (if any)	LS
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	MC-...a; MC-...a/4; MT.../2H; MT.../3H; MT.../3K; MT.../3D; UR-02; UA-1
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificates replaces certificate NL-31652/A3 date of issue 2016-03-03 and CB NL-44132 date of issue 2016-11-11. MC-600a model added. Date of first issue 2017-03-14. M2 version: AC1 ratings updated to Ue of 1000 V (2019-04-10)
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2009, IEC 60947-4-1:2009/AMD1:2012, IEC 60947-5-1:2003, IEC 60947-5-1:2003/AMD1:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2228186.50 (AC1 ratings at 1000 V), 2163435.50 up to-65; 2163435.70 up to -77 and 2163435.90; 2194774.50 up to 59

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands


